Product fiche according to Commission Regulation (EU) 1254/2014

•	Cuprier name		Nuciro		
a h	Supplier name Model	Nuaire MRXBOXAB-ECO2			
b c		Cold			
L	Specific energy consumption and SEC class $C_{\rm SEC}$ ($\mu(\mu) + \mu_{\rm SEC}^2$ a)		Average		
	SEC (KWh/m ² .a)	-86.8	-42.7	N/A	
d	SEC Class		A+ A+ N/A		
d	RVU or NRVU / Unidirectional or bidirectional	RVU / Bi-directional			
e	Type of drive (multi-speed drive or variable speed drive)	Variable speed drive			
f	Type of heat recovery system (recuperative, regenerative,	valiable speed unive			
'	none)	Recuperative			
g	Thermal efficiency of heat recovery		86%		
h	Maximum flow rate (m ³ /h)		289		
i	Electric power input of the fan drive at maximum flow rate	203			
	(W)	148			
i	Sound power level (LWA)	44			
k	Reference flow rate (m ³ /s)	0.056			
Т	Reference pressure difference (Pa)		50		
m	Specific power input (SPI) (W/(m ³ /h))		0.252		
n	Control factor and control typology	0.65 based on boost by local light			
	control factor and control typology		-	ical light	
•	Maximum internal and automal lookage rates (%)		switches	مسما	
0	Maximum internal and external leakage rates (%) Mixing rate of non-ducted bidirectional ventilation units not	< 5% Internal, <5% External			
р	intended to be equipped with one duct connection on either				
	supply or extract air side		N/A		
q	Position and description of visual filter warning for RVUs				
Ч	intended for use with filters, including text pointing out the				
	importance of regular filter changes for performance and	Refer to I&N	Refer to I&M instructions supplied		
	energy efficiency of the unit	with the unit			
r	For unidirectional ventilation systems, instructions to install				
	regulated supply/exhaust grilles in the façade for natural air				
	supply/extraction		N/A		
s	Internet address for pre-/dis-assembly instructions	www.nuair	www.nuaire.co.uk/disassembly_		
		instructions			
t	For non-ducted units only: the airflow sensitivity to pressure				
	variations at + 20 Pa and – 20 Pa		N/A		
u	For non-ducted units only: the indoor/outdoor air tightness in				
	m ³ /h		N/A		
v	The annual electricity consumption (AEC) (in kWh				
	electricity/a)		1.34		
w	The annual heating saved (AHS) (in kWh primary energy/a)	Cold	Average	Warm	
		90.2	46.1	N/A	

061068